



OFI Technologie & Innovation GmbH
Firmensitz: 1030 Wien, Arsenal, Franz-Grill-Straße 5
t: +43 1 798 16 01 - 0 | office@ofi.at | www.ofi.at

Datwyler Sealing Solutions Italy S.p.A.
Via Castello 14A
IT – 24060 Viadanica

Test Certificate

based on DVGW sheet W 270

„Microbial Enhancement on Materials to Come into Contact with Drinking Water – Testing and Assessment“ (Issue 2007)

Test Institute: OFI Technologie & Innovation GmbH
Brehmstraße 14A
AT - 1110 Wien

Date of testing: 2017-06-01 to 2017-08-24

Test order: 1701819 / 1833 / 1H

Product(s): test plates

Material: *Compound “N70N06G”*

Appraisal

Based on the performed test and its results (OFI Test report 1701819 / 1833 / 1H, 2017-09-07) and on condition of professional processing the material

“Compound N70N06G”

is suitable to be used in direct contact with drinking water as large-area seals with respect to microbial growth.

The validity of this test certificate ends with **2022-09-07** – this under the presumption that no changes in the production or manufacturing process or the basic material are made, with the exception of routine adjustments; in case of changes in the relevant legislations and/or normative regulations, which require a new test on the product, this test certificate loses its validity.

Vienna, 2017-09-07

Christoph Wirrer, BSc
Director in charge
Materials in contact with drinking water

Datwyler Sealing Solutions Taliansko S.p.A.
Via Castello 14A
IT – 24060 Viadanica

Osvedčenie o skúške

podľa **DVGW list W 270**

„Mikrobiálne vylepšenie materiálov prichádzajúcich do kontaktu s pitnou vodou - testovanie a hodnotenie“ (Vydanie 2007)

Skúšobný ústav: OFI Technologie & Innovation GmbH
Brehmstrase 14A
AT – 1110 Wien (Viedeň)
Dátum skúšky: od 1.6. 2017 do 24.8. 2017
Skúšobná objednávka: 1701819 / 1833 / 1H
Výrobok/výrobky: testovacie platne
Materiál: zmes „N70N06G“

Posúdenie

Na základe vykonaného testu a jeho výsledkov (OFI osvedčenie o skúške 1701819/1833 / 1H, 2017-09-07) a na základe stavu odborného spracovania materiálu

„Zmes N70N06G“

je vhodná na použitie v priamom kontakte s pitnou vodou ako veľkoplošné tesnenie s ohľadom na mikrobiálny rast.

Platnosť tohto osvedčenia o skúške končí 7.9. 2022 – a to za predpokladu, že vo výrobe alebo vo výrobnom procese alebo v základnom materiáli nebudú vykonané žiadne zmeny, s výnimkou bežných úprav; v prípade zmien v príslušných právnych predpisoch a / alebo normatívnych nariadeniach, ktoré si vyžadujú novú skúšku výrobku, stráca tento certifikát o skúške platnosť.

Viedeň, 2017-09-07